


DOMESTIC WATER & FIRE PROTECTION DEMO PLAN (BUILDING 200 SUB BASEMENT)

## GENERAL NOTES:

- 1. THE INFORMATION PERTAINING TO EXISTING CONDITIONS SUCH AS LOCATIONS OF FIXTURES, EQUIPMENT, PIPING AND OTHER BUILDING CONDITIONS HAS BEEN BASED ON "AS-BUILT" RECORDS AND FIELD VERIFICATION WITH LIMITED ACCESS. LAYOUT AND DISTRIBUTION OF PIPING SHOWN MAY BE DIFFERENT THAN IN THE FIELD.
- 2. THE CONTRACTOR IS RESPONSIBLE FOR ALL CUTTING AND PATCHING REQUIRED FOR INSTALLATION OF PIPING AND ACCESSORIES. ALL PENETRATIONS THROUGH FIRE RATED WALLS AND FLOORS SHALL BE PROPERLY FIRESTOPPED. METHOD OF FIRESTOPPING SHALL BE REVIEWED AND APPROVED BY ENGINEER PRIOR TO INSTALLATION.
- 3. PLUMBING PIPING AND ACCESSORIES INDICATED AS DASHED SHALL BE DEMOLISHED. PROTECT ENDS OF PIPING FOR FUTURE RECONNECTION.
- 4. THE CONTRACTOR SHALL MAINTAIN SERVICE TO EXISTING FIXTURES WHICH SUPERCEDES ANY DEMOLITION OR REROUTING INDICATED. NOTIFY ENGINEER OF ANY CONFLICTS.
- 5. ITEMS TO BE REMOVED SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED FROM THE SITE, UNLESS NOTED OTHERWISE.
- 6. INFORMATION SHOWN SOLID, WITH LIGHT LINETYPE REFERENCES EXISTING CONDITIONS AND SHALL REMAIN UNLESS NOTED OTHERWISE.
- 7. THE CONTRACTOR SHALL COORDINATE ALL SHUT-DOWNS AND TIE-INS WITH OWNER PRIOR TO BEGINNING WORK. REFER TO SPECIFICATION SECTION 010000 GENERAL REQUIREMENTS FOR SHUT-DOWN REQUIREMENTS AN PROCEDURES.
- 8. ALL EXISTING FIRE SUPPRESSION COMPONENTS SHALL REMAIN IN SERVICE UNLESS OTHERWISE NOTED.
- 9. CONTRACTOR TO SUBMIT ALL PIPE ROUTING TO THE A/E, COTR, AND PIPE SHOP PRIOR TO CONSTRUCTION.



	## Single Source. Sound Solutions.  Architecture   Engineering   Planning  Www.thesigmagroup.com  1300 Work Sanal Street  Hammel, Green and Abrahamson, Inc.	PHASE 2 - BUILDING 200 BASEMENT BUILDING WATER SERVICE DEMO PLAN	VA MEDICAL CENTER REPLACE EXISTING WATER MAINS PROJECT		Date MAY 22, 2012  Project No. VA#69PD-RA-1465	
	www.thesigmagroup.com 1300 West Canal Street Milwaukee, WI 53233 Phone: 414-643-4200 Fax: 414-643-4210  Attentecture   Engineering   Franking   Hammel, Green and Abrahamson, Inc.  333 East Erie Street Milwaukee, Wisconsin USA 53202 Fax: 414-643-4210  Telephone 414.278.8200 Facsimile 414.278.7734	Approved: Division Chief	Building Number Checked R.RUFF	Drawn	HGA#2606-008-00  DRAWING NO.	Facilities  Management
Revisions Date	PHASE 2 - CONSTRUCTION DOCUMENTS: MAY 22, 2012	Approved: Service Director	Location HINES, ILLINOIS		200-PL-101 of	